



Sustainable Integrated Grid Initiative (SIGI): *Technical and Economic Challenges of Integrating Renewable Energy, Electric Vehicle Charging and Battery Energy Storage in a Modern Grid*


**The International Cost Estimating and Analysis Association (ICEAA)
Southern California Chapter
September 9, 2015**

**Dr. Sadrul Ula
University of California-Riverside
Winston Chung Global Energy Center
College of Engineering-
Center for Environmental Research and Technology
sula@cert.ucr.edu; 951 781 5676
October 16, 2014**



Research Motivation

- **Solar PV and wind energy are intermittent**
- **More value if dispatchable when needed**
- **Electrical energy storage challenge with old battery technologies – slow charging & no deep cycling**
- **New rare earth Lithium-ion battery can handle very quick charging and many cycles**
- **Electric vehicles creating new demands on the grid**
- **Need smart grid technologies to overcome distribution disturbances, additional harmonics**
- **Need a test bed to further study**




- New Grid PV System
- New Grid Conduit
- Battery/Inverter Energy System
- 1 – 260 kW Inverter (AE 260TX)
- 2 – 100 kW Inverters (AE 100TX)
- L2 – EV Charger

1 ft = .008"

UC Riverside Solar, Battery Energy Storage and EV Charging System

Solar PV
3.5 MW UCR West Campus
0.5 MW CE-CERT

Battery Storage
1.08 MWh BCOE WCH
1.08 MWh CE-CERT/Bourns, Inc.
EV Chargers (green)





1.1 MWh Lithium-ion battery at UCR






Stationary Battery System 500kWh






SIGI Mobile Battery Energy Storage Trailer

- 500 kWh storage
- 100 kW on board inverter/charger
- 480 V 3-phase plug in for charging and delivery
- 144 Lithium batteries each weighing 77 lbs
- 8'x24' triple axle trailer




UCR Battery Testbed






Grid-tied Battery Inverter: 100kW





CE-CERT APL Building Electrical Layout 1086 Columbia

Figure 2: CE-CERT APL Building Electrical Layout (1086 Columbia Ave.)



Solar PV Inverters: 2x100kW & 260kW





APL Building Power Demand and Solar Production





California's Duck Curve




26 Level-2 chargers placed all throughout the city of Riverside, the chargers will service fleet and private vehicles



Level-3 chargers will be installed in the Fall of 2014 and service the electric trolley and other fast charging vehicles



EV Demand / Building Peak Supplied by Battery Energy Storage



Public Utilities

- Public Utilities Home
- Pay My Utility Bill
- Customer Service
- Administration ▼
- Board of Public Utilities ▼
- Residential Rebates
- Commercial Rebates
- Community Services ▼
- Electric Utility Information ▼
- Water Utility Information ▼
- Green Riverside
- News Archive
- Employment ▼
- CEQA Documents
- Department Results
- Contact Public Utilities



▼ RIVERSIDE PUBLIC UTILITIES PROVIDES RECORD ENERGY DEMANDS DURING CONTINUED TRIPLE DIGIT HEAT WAVE

9/15/2014

Riverside, Calif. – As triple digit temperatures continued to heat up Southern California to start the work week, Riverside Public Utilities (RPU) reached a new all-time high of energy provided to its customers surpassing 610 megawatts (MW).

Monday's peak surpasses the utility's previous one day all-time total for energy used which occurred on August 30, 2007 when RPU provided more than 609 MW (one megawatt is enough energy for about 650 homes).

"Our energy delivery and generation crews recognized that more energy would be needed as this week began," said RPU Assistant General Manager of Energy Delivery Pat Hohl. "Crews were at the ready, and we were able to start up our generation plants within the city to ensure there was enough power to meet the needs of our customer-owners."

Over the past decade, RPU has worked to build and acquire power plants that are located within the city of Riverside that can provide up to 192 MW of power to meet peak energy demands.

For additional information about Riverside Public Utilities, follow us on Facebook or Twitter

[Faculty] [On behalf of VC Coley] Voluntary Electricity Curtailment Notice

DELETE REPLY REPLY ALL FORWARD




faculty-bounces@scotmail.ucr.edu on behalf of Karen A Springer <karen.springer@scotmail.ucr.edu> mark as unread

Thu 9/18/2014 8:37 AM

To: faculty@scotmail.ucr.edu; msoadm@scotmail.ucr.edu; staff@scotmail.ucr.edu; students@scotmail.ucr.edu;

- This message was sent with High importance.
- You forwarded this message on 10/15/2014 7:42 PM.

1 attachment



Faculty, Staff, and Students,

You may be aware that California hit an all-time record in electrical consumption yesterday. As a result our electrical provider, Riverside Public Utility, has asked us to voluntarily curtail any non-essential electrical use between the hours of 2:00 p.m. and 5:00 p.m. In order to protect our electrical grid and be proactive in the prevention of mandatory curtailment and/or brown outs, we are asking that every member of our UCR community do their part by turning off any non-essential appliances and lights. This curtailment request will be valid throughout this current heatwave.

Thank you in advance for your understanding and participation.

Ron T. Coley
Vice Chancellor
Business and Administrative Services
3125 Hinderaker Hall
(951) 827-3268




SIGI helps RPU ride through peak historic demand

- As triple digit temperatures continued to heat up Southern California to start the work week, Riverside Public Utilities (RPU) reached a new all-time high of electrical energy provided to its customers surpassing 610 megawatts (MW).
- Monday September 15, 2014's peak surpasses the utility's previous one day all-time total for energy used which occurred on August 30, 2007 when RPU provided more than 609 MW (one megawatt is enough energy for about 650 homes).
- In response to an appeal by RPU to conserve electrical energy, UCR officials requested faculty, staff and students to take actions to help reduce electricity use, specially between 2 pm to 5 pm.



09/19/2014 - CAEE Building - Power Usage

— CAEE Building — Solar Inverter 3 — Battery System



CE-CERT CAEE building nominal energy use: 225kW

CE-CERT CAEE building batteries switched from charging to discharging to grid: net 200kW


CE-CERT CAEE building energy use after savings actions: -90kW

CE-CERT CAEE solar diverted to grid: 75kW

Non-essential air handlers curtailed: 40kW

09/19/2014 - CAEE Buildings - Power Usage

— CAEE Building — Solar Inverter 3 — Battery System





SIGI helps RPU during peak historic demand

September 19, 2014:

- **Triple digit temperatures lead to Riverside Public Utilities (RPU) reaching a new all-time high electricity demand of 610 megawatts (MW).**
- **RPU send out an appeal to larger customers to conserve electrical energy, specifically between 2 pm to 5 pm.**
- **CE-CERT's Sustainable Integrated Grid Initiative (SIGI) Testbed provided the flexibility to not only curtail nominal power consumption of **365kW**, but provide **225kW** back to the grid, resulting in a **590kW** swing for three hours**
- **CE-CERT CAEE building net energy savings: **315kW****
- **CE-CERT admin building net energy savings: **95kW****
- **CE-CERT APL building net energy savings: **180kW****



Application of Battery Energy Storage for Demand Reduction

| ELECTRICITY | |
|--|--|
| Customer Charges For Electricity | |
| 5640 | 5640 KWH (ON PEAK EL)@\$0.103300 = 582.61 |
| 102.00 KW | 102.00 KW (ON PEAK DM)@\$6.880000 = 701.76 |
| 7640 | 17640 KWH (MID PEAK E)@\$0.082800 = 1,460.59 |
| 126.00 KW | 126.00 KW (MID PEAK D)@\$2.740000 = 345.24 |
| 2080 | 22080 KWH (OFF PEAK E)@\$0.072700 = 1,605.22 |
| 92.40 KW | 92.40 KW (OFF PEAK D)@\$1.310000 = 121.04 |
| | CUSTOMER CHARGES 704.66 |
| | RELIABILITY CHARGE 1,100.00 |
| | STATE ENERGY 13.16 |
| 12/05/12 TOTAL CHARGES FOR ELECTRICITY \$6,634.28 | |

| ELECTRICITY | |
|--|--|
| Customer Charges For Electricity | |
| 5160 | 5160 KWH (ON PEAK EL)@\$0.103300 = 533.03 |
| 106.80 KW | 106.80 KW (ON PEAK DM)@\$6.880000 = 734.78 |
| 20160 | 20160 KWH (MID PEAK E)@\$0.082800 = 1,669.25 |
| 222.00 KW | 222.00 KW (MID PEAK D)@\$2.740000 = 608.28 |
| 23640 | 23640 KWH (OFF PEAK E)@\$0.072700 = 1,718.63 |
| 93.60 KW | 93.60 KW (OFF PEAK D)@\$1.310000 = 122.62 |
| | CUSTOMER CHARGES 704.66 |
| | RELIABILITY CHARGE 1,100.00 |
| | STATE ENERGY 14.21 |
| 12/05/13 TOTAL CHARGES FOR ELECTRICITY \$7,205.46 | |

| Customer Charges for Electricity | |
|--|---|
| 1,320 KWH | 1,320 KWH (ON PEAK EL)@\$0.103300 = 136.36 |
| 12.00 KW | 12.00 KW (ON PEAK DM)@\$6.880000 = 82.56 |
| 11,520 KWH | 11,520 KWH (MID PEAK E)@\$0.082800 = 953.88 |
| 163.20 KW | 163.20 KW (MID PEAK D)@\$2.740000 = 447.17 |
| 28,920 KWH | 28,920 KWH (OFF PEAK E)@\$0.072700 = 2,102.48 |
| 175.20 KW | 175.20 KW (OFF PEAK D)@\$1.310000 = 229.51 |
| | RELIABILITY CHARGE 1,100.00 |
| | CUSTOMER CHARGES 704.66 |
| | STATE ENERGY 12.11 |
| 12/02/14 TOTAL CHARGES FOR ELECTRICITY \$5,768.71 | |

Results from a 500 kWh, 100 kW lithium-ion Winston Battery System

Peak Demand

2012= 102 kW

2013= 106 kW

*** SIGI Installed ***



2014 = 12 kW

(Monthly Cost Savings ~\$1,000 In RPU Territory; ~\$2,500 in SCE)





One-Day Experiment with Three Different Time Periods Control Algorithms





Cost Analysis

Comparisons Between Different System Architectures

| System Comparison | Energy kWh Savings(\$) | Load Demand Savings(\$) | | | Total (\$) |
|---------------------------|------------------------|-------------------------|----------|----------|------------|
| | | On-Peak | Mid-Peak | Off-Peak | |
| Real vs. Schedule | 209.65 | 105.92 | 17.24 | 6.19 | 339.00 |
| Real vs. No Battery | 104.38 | 381.12 | 17.24 | -33.10 | 469.64 |
| Real vs. No PV or Battery | 1182.82 | 584.56 | 126.26 | -27.21 | 1866.43 |

June 2015 Electricity Cost Comparison for Different System Architectures


| Different Situation | Energy kWh Savings(\$) | Load Demand Savings(\$) | | | Total (\$) |
|---------------------------|------------------------|-------------------------|----------|----------|------------|
| | | On-Peak | Mid-Peak | Off-Peak | |
| Real vs. Schedule | 84.26 | 59.5 | 0 | 14.6 | 158.36 |
| Real vs. No Battery | 97.44 | 472.3 | 24.84 | -24.7 | 594.58 |
| Real vs. No PV or Battery | 953.7 | 585.65 | 115.44 | -24.7 | 1630.09 |

May 2015 Electricity Cost Comparison for Different System Architectures

Real refers to real-time control algorithm




Demand Comparisons



B1200 On-Peak Demand in Electricity Bill



2012-2014 Sep-Dec Building 1200 Max Demand On Peak





Do We Understand Our Electric Bills?



**Which Unit is Time Dependent:
kilo-Watt (kW) or kilo-Watt hour (kWh)?**



Do We Understand Our Electric Bills?

1 in 10 of us?

.....

**Which Unit is Time Dependent:
kilo-Watt (kW) or kilo-Watt hour (kWh)?**

Watt = Joules/second: kW is time dependent



Anaheim Public Utilities Rate Schedule


| Lifeline Usage | Per Meter, Per Month |
|---|----------------------|
| Customer Charge | \$3.37 |
| Energy Charge (to be added to Customer Charge): | |
| First 270 kWh, Basic Lifeline per kWh | 10.88¢ |
| Plus 125 kWh for Electric Water Heating, per kWh | 10.88¢ |
| Plus 275 kWh for Electric Space Heating, for November 1 through April 30, per kWh | 10.88¢ |
| Plus all kWh for Life Support Allowance, per kWh | 10.88¢ |
| Non-Lifeline Usage: | |
| All kWh in excess of the above, per kWh | 16.11¢ |
| Minimum Charge: | |
| The minimum charge shall be the monthly Customer Charge. | |



Anaheim Public Utilities Details of Electric Charges

6/22/15 – 8/19/15

| ELECTRIC CHARGES | | CONSUMPTION | |
|-------------------------------|-----------------------|-------------|-----------------|
| | CUSTOMER CHARGE | | \$6.52 |
| | BASIC LIFELINE | 522 KWH | \$56.79 |
| | ADDITIONAL 500 MED | 967 KWH | \$105.21 |
| | NON LIFELINE | 919 KWH | \$148.05 |
| | UNDERGROUND SURCHARGE | | \$12.66 |
| | RATE STABILIZATION | | \$54.50 |
| Total Electric Charges | | | \$383.73 |






Electricity Charge for Anaheim Public Utilities Customers

\$384 Present Use

6/22/2015 – 8/19/2015






Electricity Charge for Anaheim Public Utilities Customers

\$74 With 100% Energy Coming From Solar

6/22/2015 – 8/19/2015





ENERGY STATEMENT

www.pge.com/MyEnergy

Account No: ~~80104212224~~

Statement Date: 06/19/2015

Due Date: 07/06/2015

RECEIVED JUN 26 2015

Service For:

10/28
~~CVM COMPANY A DIVISION OF ABI~~
~~2651 FLORENCE AVE STE~~
~~BACK OF PROPERTY~~
~~FRESNO, CA 93721~~

Your Account Summary

2824 06 19 15

| | |
|--|-------------|
| Amount Due on Previous Statement | \$68,742.82 |
| Payment(s) Received Since Last Statement | -68,742.82 |
| Previous Unpaid Balance | \$0.00 |
| Current Electric Charges | \$60,630.80 |

Total Amount Due by 07/06/2015 \$60,630.80


Questions about your bill?

24 hours, 7 days/wk 1-800-468-4743
 Business Specialist available:
 Mon-Sat: 7am to 9pm
 www.pge.com/MyEnergy

Local Office Address

705 P ST
 FRESNO, CA 93721

ENT'D JUN 29 2015





05/21/2015 – 06/19/2015

| | | | | |
|---|----------------|------|--------------|--------------------|
| Customer Charge | 30 | days | @ \$32.85421 | \$985.63 |
| Demand Charge | | | | |
| Max Peak | 760.000000 | kW | @ \$18.53000 | 14,082.80 |
| Max Part Peak | 704.000000 | kW | @ \$4.03000 | 2,837.12 |
| Max Demand | 760.000000 | kW | @ \$14.71000 | 11,179.60 |
| Energy Charges | | | | |
| Peak | 67,200.000000 | kWh | @ \$0.14772 | 9,926.78 |
| Part Peak | 74,400.000000 | kWh | @ \$0.10275 | 7,644.60 |
| Off Peak | 189,600.000000 | kWh | @ \$0.07311 | 13,861.66 |
| Power Factor Adjustment (@ 84.00% Power Factor) | | | | 16.56 |
| Energy Commission Tax | | | | 96.05 |
| Total Electric Charges | | | | \$60,630.80 |



Rate Schedule for Customers with Max Demand of over 1000 kW

| | Secondary Voltage |
|---|----------------------|
| <u>Total Customer/Meter Charge Rates</u> | |
| Customer Charge Mandatory E-20 (\$ per meter per day) | \$32.85421 |
| Optional Meter Data Access Charge (\$ per meter per day) | \$0.98563 |
| <u>Total Demand Rates (\$ per kW)</u> | |
| Maximum Peak Demand Summer | \$18.53 (I) |
| Maximum Part-Peak Demand Summer | \$4.03 |
| Maximum Demand Summer | \$14.71 (I) |
| Maximum Part-Peak Demand Winter | \$0.27 |
| Maximum Demand Winter | \$14.71 (I) |
| <u>Total Energy Rates (\$ per kWh)</u> | |
| Peak Summer | \$0.14772 (R) |
| Part-Peak Summer | \$0.10275 (R) |
| Off-Peak Summer | \$0.07311 (R) |
| Part-Peak Winter | \$0.09636 (R) |
| Off-Peak Winter | \$0.07431 (R) |



Definition of Time Periods for PG&E


| | | |
|---------------|---|---|
| SUMMER | Period A (Service from May 1 through October 31): | |
| Peak: | 12:00 noon to 6:00 p.m. | Monday through Friday (except holidays) |
| Partial-peak: | 8:30 a.m. to 12:00 noon AND 6:00 p.m. to 9:30 p.m. | Monday through Friday (except holidays) |
| Off-peak: | 9:30 p.m. to 8:30 a.m. All day | Monday through Friday Saturday, Sunday, and holidays |
| WINTER | Period B (service from November 1 through April 30): | |
| Partial-Peak: | 8:30 a.m. to 9:30 p.m. | Monday through Friday (except holidays) |
| Off-Peak: | 9:30 p.m. to 8:30 a.m. All day | Monday through Friday (except holidays) Saturday, Sunday, and holidays |



Electricity Charge for a PG&E Industrial Customer

\$60,632 Present Use

5/21/2015 – 6/19/2015






Electricity Charge for a PG&E Industrial Customer

\$29,198 With 100% Energy Coming From Solar

5/21/2015 – 6/19/2015





Conclusions

- **Solar and wind energy are intermittent**
- **Dispatch-able electricity require storage**
- **New Lithium batteries offer opportunities**
- **EV charging strains power distribution system**
- **UCR's Sustainable Integrated Grid Initiative (SIGI) test-bed offer plug and play capabilities**
- **Testing and validation results give confidence to electric utilities for rapid adoption**
- **UCR's researchers and students offer electrical efficiency studies, analysis and help with new technology adoption to industries**



Thank you

Questions?