



Arnold Engineering Development Center



Researching, Developing, and Testing America's Aerospace Technology



Economic Analysis Process Applied To The Worlds' Largest Wind Tunnel

Arnold AFB

Integrity - Service - Excellence



Economic Analysis Process Applied To The Worlds' Largest Wind Tunnel



Presented by

**1Lt Dan Wyman
AEDC/FMP**

dana.wyman@arnold.af.mil

**Robert Nelson
AEDC/FMP MCR, LLC**

robert.nelson@arnold.af.mil

ISPA-SCEA 2007 Joint Conference

June 12 – 15, 2007



Arnold Engineering Development Center (AEDC)



AEDC is the World's Largest Complex of Wind Tunnels and Simulation Facilities

Located in Tullahoma, Tennessee

Established in 1950

56 Interrelated Plant Systems and Test Facilities

AEDC is a Major Range & Test Facility Base (MRTFB)

Arnold

Eglin

Edwards

AEDC is Undr USAF Management with Contractor Workforce

8% Government, 92% Contractor

2,978 Total Personnel



AEDC – Aerial View





AEDC Detail View 1





AEDC Detail View 2





RC-1 Cooler






RC-1 Diagram



RC1 LOW STAGE COOLER





Some RC-1 Cooler Information



1,200 lb/second of ambient air brought in by compressors

About the volume of a 2,100 sq ft house

Exits at 300°F.

RC-1 cools and dries the air to simulate conditions at high altitude and prevent ice from forming

Cools to -25°F

Humidity reduced up to 99.6% (over 3 gal/sec.)

Downstream compressors “suck out” the air creating low pressure & low humidity high altitude conditions.

Cold Dry Low Pressure Air Moving Really Fast



RC-1 Cooler Concern



1970s design

- Mechanical refrigeration

- Pressurized dehumidification cooler

- Time - worn out

- Could be a single-point-of-failure

- Environmental issues

 - 24,000 lbs of Freon (R12)

 - Ozone depletion

 - 50,000 gallons of trichloroethylene (TCE)

 - Affects the central nervous system

 - Damage nerves, liver, kidneys, cause cancer



RC-1 Cooler Task



Identify an approach to restore the RC-1 Cooler that:

Meets current operational performance capabilities

Eliminates single-point-of-failure

Removes TCE as the brining agent

Removes R12 as the refrigerant.



Economic Analysis – Point 1



Those who are accomplishing the EA need and understanding of the technical attributes and features of the system for which the EA is being accomplished.



Options Considered



- Mechanical Drying
 - Refrigerant System Upgrade with R12 & Dynalene HC40, new refrigeration system, new RC1 coils
 - Refrigerant System Upgrade with Ammonia & Dynalene HC40, new refrigeration system, new RC1 coils)
 - Four New Coolers (one cooler for each compressor)
 - One New Cooler (“RC-1B” parallel cooler)
- Desiccant Drying
 - Desiccant Wheels (Parallel or Series)
 - Liquid or Multi-bed Desiccants
- Others
 - Cryogenic Dehumidification System (Liquid Air)
 - Desiccant Wheels added to low-stage desiccant wheel
 - Maintain Status Quo



Two Options Selected Further Study




- Mechanical Drying
 - Refrigerant System Upgrade
 - R12 to R507A
 - TCE to Dynalene HC40
 - New industrial refrigeration system
 - New RC1 coils)

- Desiccant Drying
 - Desiccant Wheels (Parallel)



Mechanical Drying






AEDC

Refrigerant System Upgrade



RC-1 LOW STAGE COOLER



3rd and 4th Stages

- Dynalene HC40 replaces TCE
- R507A Refrigerant replaces R12



Refrigerant System Upgrade



Life Cycle Cost

Known maintenance costs

System sustainment costs will mirror current costs


15-20% more pumping power required for

Dynalene over TCE

Risk that use of selected fluids (R507A refrigerant and Dynalene HC40 brine) will be restricted later




Desiccant Drying





AEDC


Desiccant Wheel Principal





AEDC

Desiccant Wheels






AEDC

Desiccant Wheel





Desiccant Drying Equipment Installation





Desiccant Drying



Life Cycle Cost

Desiccant Dryer Quad-Units

Four 10' desiccant wheels per quad-unit

Eight 8 Quad-Units required

A total of 32 individual wheels

No commercial installation of this magnitude exists.

Commercial large dry-air --- up to 120 lbs/sec.

This concept needs 1,200 lbs/sec.!



Desiccant Drying



Life Cycle Cost

Long life of desiccant wheels (10 – 15 years)

O&M costs estimated based on power use and contractor maintenance cost data

Uncertainty of natural gas costs



Economic Analysis Approach



Construction Cost

Operations Cost

Maintenance Cost



Construction Cost Estimate Approach



Engineers estimated labor & material cost for each item.
Example of scope for one Work Package

MECHANICAL UTILITIES - Work Package 1
Replace RC14 System
Replace RC14 System
P&I new base for custom built RC14 chiller
P&I new bases for new RC14 brine pumps
Subtotal
Equipment - Replace RC14 System
P&I new custom built RC14 chiller. (includes condensers, evaporators, compressors, vessels, & related chiller piping)
Demo RC14 Coils within RC1 cooler (Coils K,L,M,N)
Demo Existing RC14 brine pumps (14.1, 14.2, 14.3, 14.4)
Demo existing RC14 brine expansion tank
P&I new brine pumps for RC14 circuit
P&I new RC14 brine expansion tank
P&I new RC14 coils within RC1 cooler Coils
Demo old RC14 chiller and remaining related RC14 equipment



Economic Analysis – Point 2



The EA analyst will develop some of the supporting cost estimates. In these cases, an understanding of the system is necessary to develop a credible cost estimate for each EA cost area.

If the estimate is provided the EA analyst must understand and concur with that cost estimate information.



Construction Cost Estimate Approach



The construction cost estimates for both approaches were close to each other.

The primary difference was that the Desiccant Wheel option construction costs are earlier than for the Mechanical Drying approach.



Operations Cost Estimate Approach



Example of calculations based on power requirements.

Calculation Approach Example Only	Comp Pwr	Elct Pwr	Nat Gas
Description	TON	BHP	CFH
Compressor power			
RC12 Stage	9000	6000	
RC13 Stage	4000	7000	
Brine Pump power			
RC12 Stage		1000	
RC13 Stage		1500	
Condenser water pumps			
RC12		1700	
RC13		700	
RC11a and RC11B		150	
RC11C		300	
Brine spray reboilers			9000
Brine spray pump #1		10	
Brine spray pump #2		10	
TOTAL:		18370	9000
TOTAL (KW) = 0.5 * TOTAL (BHP)			9,185
TOTAL (\$/HR electricity) = 0.1* TOTAL (KW)			\$ 919
TOTAL (\$/HR gas) = 0.02* TOTAL (CFH)			\$ 180
TOTAL (\$/HR) = Electricity (\$/HR) + Gas (\$/HR)			\$ 1,099
Monthly - 16hrs/day x 30 days			\$527,280



Operations Cost Estimate Approach



Mechanical Drying

Electric power requirements are large for the refrigeration system.

Desiccant Dryer

Natural gas costs for the regeneration heater is the primary component.



Maintenance Cost Estimate Approach




Mechanical Drying – based on historical costs for the current system.

Desiccant Wheel Dryers – based on contractor rates for maintenance of this equipment.

The Mx costs are lower than the Operations costs.



Net Present Value Chart





Economic Analysis – Point 3



Be be able to explain the reasons for the EA cost differences between the alternatives.



Net Present Value Observation



The construction costs were about the same except for the timing of the expenditures

The maintenance costs were both relatively low

The larger operations cost for the Mechanical Drying option causes it's NPV to become much larger over time

Operations is the NPV cost driver.



Economic Analysis – Point 4



The EA results are only one component of a decision making process. The decision process will assess and weigh several decision criteria.

An assignment of the “relative value” for each decision criteria will help in developing and defending the final decision.



Overall Evaluation Criteria



- Function (21%)
 - Simplicity, Training, Ease of Operations
- Reliability, Availability, and Maintainability
 - Operations, Degradation, Maintenance
- **Viability (12%)**
 - **Capital, Operations and Maintenance Costs**
- Supportability (10%)
 - Maintenance Requirements, Logistics Support,
- Liability (15%)
 - Safety, Hygiene, Impacts, Energy Conservation
- Acquisition Planning (10%)
 - MILCON, R&M Funds
- Technical Risk (7%)
 - Obsolescence, Mitigation, Contamination
- Schedule (5%)
 - Duration of Repair, Ops & Mx Impacts



Evaluation Matrix



Criteria		Weighting	
Functionality		21%	
Reliability, Availability and Maintainability		20%	
Viability		12%	
	Capital cost		7%
	Annual operating costs		5%
Supportability		10%	
	Annual maintenance costs		7%
	Logistics support		2%
	Freq/Amount of replacement costs		1%
Liability		15%	
Acquisition Planning		10%	
Technical Risk		7%	
Schedule		5%	



Economic Analysis Interim Results



At this point, the Desiccant Wheel approach has the smaller Net Present Value

However, also at this time (mid-March 2007) technical changes were required that will change the results.



Economic Analysis – Point 5



Systems analysis and evaluations often are dynamic. Due to technical, programmatic, funding and other concerns or constraints the alternatives are redefined.



Technical Changes



The set of alternatives was modified to three options:

Option 1: Mechanical Drying (Previous Option)

Option 2: Mechanical Drying (Previous Option)
+ High-Stage Desiccant Drying

Option 3: Desiccant Wheels (Previous Option)
+ Low Stage Mechanical Drying



Option 1: Mechanical Drying



Same as the earlier Mechanical Drying Alternative
No change in the Economic Analysis



Option 2: Option 1 + High-Stage Desiccant Drying



Add High-Stage Desiccant Drying to the Mechanical Drying Alternative.

Install 8 Desiccant Dryer Units upstream of the high stage compressors

Pre cooling coils remove about 2/3 moisture


Desiccant wheels remove remaining moisture

Regeneration with natural gas burners



AEDC


Option 2: Desiccant Dryer Unit





Option3: Desiccant Wheels + Low Stage Mechanical Drying

RC1 LOW STAGE COOLER





Option3: Desiccant Wheels + Low Stage Mechanical Drying



Add Low-Stage Mechanical Drying to the Desiccant Wheel Alternative

- Modify the existing RC1 cooler system

- Provide new cooler coils and refrigeration

- Replace the R12 and Trichloroethylene

- Replace secondary coolant & brine systems

- Replace centrifugal with screw type chillers



Economic Analysis – Point 6



Due to the often dynamic nature of the alternative process the EA process will continue to be dynamic.



Economic Analysis – Point 7



As of the submission date for this paper (April 9) the parameters associated with these changes are being defined by the members of the technical team.



Economic Analysis – Point 8



The EA process will continue upon availability of that data.

**Updated information will be provided at the
ISPA-SCEA 2007 Joint Conference
June 12-15, 2007**